



Certificate of Compliance

Certificate: 1248370

Master Contract: 187981

Project: 2752047

Date Issued: August 7, 2014

Issued to: **Beghelli North America**
3250 Corporate Way, Unit B
Miramar, FL 33025
USA
Attention: Bill Dixon

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Byron Bargas

Issued by: Byron Bargas

PRODUCTS

CLASS 3422 81 - LUMINAIRES - Gas-tube Luminaires - Certified to US Standards

CLASS 3422 01 - LUMINAIRES - Gas-tube Luminaires

Wet location, fluorescent, surface or pendant mounted luminaires, rated 120-480V, 60Hz:

BX920 - 2 ft Model (2x14W T5, 2x17W T8, 2x24W T5HO), 4 ft Model (2x32W T8, 2x28W T5, 2x54W T5HO)

BX940 - 4 ft Model (4x32W T8, 4x28W T5, 4x54W T5HO)

BX950 - 2 ft Model (2x36W CF, 2x55W CF), 4 ft Model (4x36W CF, 4x55W CF)

BX960 - 2 ft Model (2x36W CF, 2x55W CF)

The above 4 ft and 2 ft version has an option to be provided with the following CSA Certified or UL listed Emergency Fluorescent Ballast or its equivalent:

Model	Input rating	Load type	Output rating	Time base
Bodine BDL600	120V/277V, 0.28A 3.5W, 60 Hz	17W-215W T8, T10, T12	3.6V, 14.4Wh	90 minutes

Dry Location, fluorescent, surface or pendant mounted luminaires, 347V max, 60Hz, BS500 Series.



Certificate: 1248370

Master Contract: 187981

Project: 2752047

Date Issued: August 7, 2014

Available in 2 ft version with 2x17W T8 lamps, 4ft version with up to 2x32W T8 lamps or 2x14W T5 lamps, 5ft version with up to 2x54W T5 lamps max

Wet location, fluorescent, surface mounted luminaires, 120 – 347V, 60Hz, BS105 series.

Wet location, fluorescent, surface mounted luminaires, 480V max, 60Hz, BS100U, BS101, and BS111 series.

Available in 2 ft. version with up to 2-17 watt T8 lamps or up to 2-F24T5/HO lamps max, or 4ft. versions with up to 2 -32 W T8 lamps max or up to 2-F54T5/HO lamps max The above 4 ft and 2 ft version has an option to be provided with the following CSA Certified or UL listed Emergency Fluorescent Ballast or its equivalent:

Model	Input rating	Load type	Output rating	Time
base Bodine BDL600	120V/277V, 0.28A	17W-215W	3.6V, 14.4Wh	90 minutes
	3.5W, 60 Hz	T8, T10, T12		

Dry Location, Fluorescent, Pendant mount luminaire, rated 480V max, 60Hz, model SIRIUS, for use with two 54W T5HO or 58W T8 lamps.

The above has an option to be provided with the following CSA Certified or UL listed Emergency Fluorescent Ballast or its equivalent:

Model	Input rating	Load type	Output rating	Time base
Bodine LP600	120V/277V, 0.18A	14W-54W T5	8.4V, 18.4Wh	90 minutes
	3W, 60 Hz	17W-55W T8		

CLASS 3422 01 – LUMINAIRES – Gas-Tube Luminaires

CLASS 3422 02 – LUMINAIRES – Gas-Tube Luminaires

CLASS 3422 81 – LUMINAIRES – Gas-Tube Luminaires - CERTIFIED TO U.S. STANDARDS

Wet location, fluorescent, surface mounted luminaires, 120 – 347V, 60Hz, BS100 series.

Available in 2ft version with up to 2-17W T8 lamps or up to 2-24W T5/HO lamps max, or 4ft versions with up to 2-32W T8 lamps max or up to 2-54W T5/HO lamps max.

The above 4 ft and 2 ft version has an option to be provided with the following CSA Certified or UL listed Emergency Fluorescent Ballast or its equivalent:

Model	Input rating	Load type	Output rating	Time base
Bodine BDL600	120V/277V, 0.28A	17W-215W	3.6V, 14.4Wh	90 minutes
	3.5W, 60 Hz	T8, T10, T12		

CLASS 3435 82 - EMERGENCY LIGHTING EQUIPMENT - Unit Equipment - Performance - CERTIFIED TO U.S. STANDARDS

Wet location, fluorescent, surface mounted luminaires, 347V max, 60Hz, BS100U and BS101 series, Available in 2 ft. version with up to 2-17 watt T8 lamps max, or 4ft. versions with up to 2 -32 W T8 lamps max.



Certificate: 1248370

Master Contract: 187981

Project: 2752047

Date Issued: August 7, 2014

The above fixture is provided with the following CSA Certified or UL Listed Emergency Fluorescent Ballast to UL 924 with a 90 min time base or its equivalent:

Load type	Output rating	Time base	Model	Input rating	
17W-215W	3.6V, 14.4Wh	90 minutes	Bodine BDL600	120V/277V, 0.28A	T8,
T10, T12				3.5W, 60 Hz	

CLASS 3426 31 - FIXTURES AND FITTINGS - Fixture Fittings

CLASS 3426 91 - FIXTURES AND FITTINGS - Fixture Fittings

Wet Location, fluorescent, surface mounted, plastic enclosure housing Cat No BS101E.

Notes:

1. "For use only in complete equipment where the acceptability of the combination is determined by CSA or by local authorities having jurisdiction."
2. This requires the use of the CSA Component Mark

APPLICABLE REQUIREMENTS

CSA C22.2 No. 250.0-08 - Luminaires

UL 1598, 3rd Ed. 2008 - Luminaires

UL 924, 9th Ed. 2006 - Emergency Lighting and Power Equipment

CAN/CSA-E598-1-98 - Luminaires Part 1: General Requirements and Tests

CAN/CSA-E598-2-1-98 - Luminaires Part 2: Particular Requirements, Section 1: Fixed General Purpose Luminaires

TIL B-78, May 15th 2006 - Interim Certification Requirements for Ballast Disconnect Means in Fluorescent Luminaires for Installation on Branch Circuits with Voltages Exceeding 150 Volts-to-Ground