



# Certificate of Compliance

**Certificate:** 2543216

**Master Contract:** 187981

**Project:** 2622292

**Date Issued:** May 1, 2013

**Issued to:** **Beghelli North America**  
**3250 Corporate Way, Unit B**  
**Miramar, FL 33025**  
**USA**  
**Attention: Peter Shilling**

*The products listed below are eligible to bear the CSA Mark shown*



*Patrick Hew*

**Issued by:** Patrick Hew

## PRODUCTS

**CLASS 3435 82** - EMERGENCY LIGHTING AND POWER EQUIPMENT - Certified to US Standards

**CLASS 3435 02** - EMERGENCY LIGHTING AND POWER EQUIPMENT

**CLASS 3435 02** - EMERGENCY LIGHTING EQUIPMENT - Unit Equipment - Performance

Ceiling or wall mounted emergency Lighting Fixtures, Bravado Series BRV, Input rated: 120/277/347 Vac; 0.25 /0.1/0.09A (max), with 2 integral emergency lighting heads and 2 optional output lines rated: 6 or 12 Vdc, for a total of 160 Watts Max total lamp output including remote lamps. Suitable for a minimum 30 minute emergency run time, with type 4X enclosure.

Series BRV: - (2) 7W, 12V LED Bi-pin lamp

- (2) 10W, 6V MR16 Tungsten Halogen lamp
- (2) 12W, 6V MR16 Tungsten Halogen lamp
- (2) 20W, 6V MR16 Tungsten Halogen lamp
- (2) 35W, 12V MR16 Tungsten Halogen lamp



**Certificate:** 2543216

**Master Contract:** 187981

**Project:** 2622292

**Date Issued:** May 1, 2013

---

- (2) 50W, 12V MR16 Tungsten Halogen lamp

CLASS 3435 82 - EMERGENCY LIGHTING EQUIPMENT - Unit Equipment - Performance - Certified to U.S. Standards

Ceiling or wall mounted emergency Lighting Fixtures, Bravado Series BRV, Input rated: 120/277/347 Vac; 0.25 /0.1/0.09A (max), with 2 integral emergency lighting heads and 2 optional output lines rated: 6 or 12 Vdc, for a total of 160 Watts Max total lamp output including remote lamps. Suitable for a minimum 90 minute emergency run time.

Series BRV: - (2) 7W, 12V LED Bi-pin lamp

- (2) 10W, 6V MR16 Tungsten Halogen lamp

- (2) 12W, 6V MR16 Tungsten Halogen lamp

- (2) 20W, 6V MR16 Tungsten Halogen lamp

Notes:

- 1) The Catalog Number designation is detailed in the report body and is followed by alphanumeric suffixes denoting electrical and mechanical variations.
- 2) The Emergency lighting Units (Cat no. BRV-R series) are available as remote or integrally mounted lighting heads
- 3) Units may be provided with or without conduit hubs.
- 4) Each units may have two (2) Emergency Lighting Heads, rated 6 or 12Vdc, using 50W (max) Halogen lamps or 7W (max) LED lamps.

**APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No 250.0-00 - Luminaires

CAN/CSA-C22.2 No 250.13-2012 - Light Emitting Diode (LED) Equipment for Lighting Applications

CSA Standard C22.2 No 141-10 - Unit Equipment for Emergency Lighting

CSA Standard C22.2 No 94 - M91 - Special Purpose Enclosures

UL 1598 3rd Edition 2010 - Luminaires

UL 924 Ninth edition - UL Standard for Safety Emergency Lighting and Power Equipment



**Certificate:** 2543216

**Master Contract:** 187981

**Project:** 2622292

**Date Issued:** May 1, 2013

---

UL 8750 - Light Emitting Diode (LED) Equipment for Use in Lighting Products