




# Certificate of Compliance

**Certificate:** 70082044 **Master Contract:** 187981 (110823\_0\_000)  
**Project:** 70082044 **Date Issued:** 2016-06-14  
**Issued to:** **Beghelli North America**  
**3250 Corporate Way**  
**Miramar, Florida 33025**  
**USA**  
**Attention: Wenceslao Garro**

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** *David Lemaux*  
David Lemaux

## **PRODUCTS**

CLASS - C340202 - LUMINAIRES - LED-Surface Mounted

CLASS - C340282 - LUMINAIRES - LED-Surface Mounted - Certified to US Stds

CLASS - C342635 - LUMINAIRES - Luminaire Fittings-Retrofit Kits for Luminaires

CLASS - C342695 - LUMINAIRES-Luminaire Fittings-Retrofit Kits for Luminaires - Certified to US Standards

Models BS100LED, BS101LED, SCA (SCALA) - LED Surface mount Luminaires, suitable for Wet Locations, rated 120V-480V, 50/60Hz, 80W max for 4 ft luminaire, 60W max for 2 ft luminaire. May be mounted with hook mount, aircraft cable, Chain, stem pendant mount, junction box mount, pivot, or swivel stem mount. May be provided with optional Motion Sensor, Surge protector, wire guard, fuse, wireless controllers, emergency driver, and lower reflector lens. Provided with additional suffixes denoting options.

Model RK – LED Retrofit Kit, rated 120V-480V, 50/60Hz, 80W max for 4 ft luminaire, 60W max for 2 ft luminaire. May be provided with optional Motion Sensor, Surge protector, fuse, wireless controllers, and emergency driver. Provided with additional suffixes denoting options.

## **CONDITIONS OF ACCEPTABLE USAGE:**

When installed in the end-use equipment, the following are among the considerations to be made:

1. These products are for use only in (or with) complete end product equipment where the acceptability of the combination is determined by authorities having jurisdiction.



**Certificate:** 70082044

**Project:** 70082044

**Master Contract:** 187981

**Date Issued:** 2016-06-14

---

2. Consideration shall be given to verification of the wiring configuration during end product evaluation.
3. Consideration shall be given to verification that the Retrofit kit mounting is suitable and adequate when installed into end product.
4. This product is suitable for use in dry, damp, and wet locations.

### **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 250.0-08 – Luminaires

UL 1598, 3<sup>rd</sup> Ed. – Luminaires

CSA C22.2 No. 250.13-14 – Light Emitting Diode (LED) Equipment for Lighting Applications

UL 8750, 2<sup>nd</sup> Ed. – Light Emitting Diode (LED) Equipment for use in Lighting Products

CSA TIL B-79A – Retrofit Assemblies for Use in Luminaires

UL 1598C, 1<sup>st</sup> Ed – Light-Emitting Diode (LED) Retrofit Luminaire Conversion Kits



## *Supplement to Certificate of Compliance*

**Certificate:** 70082044

**Master Contract:** 187981 (110823\_0\_000)

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70082044	2016-06-14	Addition of alternate LED drivers, LED modules to BS100 series; combine reports 2506158 and 2513746.